

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3240-0065:140 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: Faraday Inc., 805 South Maumee St., Tecumseh, MI 49286
Contact: Steven A. Blohm (517) 423-2111

DESIGN: Models 8930, 8931, 8980, 8981, 8976, 8898, 8840, 8839 and *8817 duct smoke detectors.
Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances
and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or registered trademark "FOS", model number, electrical rating and UL label.

APPROVAL: Listed as duct detectors for use with HVAC systems having air velocities between 500 fpm
to 4000 fpm when used with separately listed compatible control units. Model 8931 may be
used in systems having air velocities of 300 fpm to 4000 fpm.

XLF: 3240-0067:116

*Rev. 07-26-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 26, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager